

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1070844

Product: Electrical installation relay

Type: PR116, PR208

Rating: Coil AC/DC 24 V, AC 230 V, Contacts AC 250 V, 8 A, 16 A

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 703784-01/01 of: 11.10.2007

A sample of the product was found to be in conformity with:
ČSN EN 60669-2-2:98+A1:99+Z1:07, ČSN EN 55022:99+A1:01+A2:03+3:05+4:05+Z1:07,
ČSN EN 61000-6-1:02+Z1:07, ČSN EN 60669-2-2:07, ČSN EN 55022:07 ed. 2

The validity of the certificate is limited to: 31.10.2010

19.10.2007

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



703784-01