

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1100739

Product: Fuse-base for cylindrical fuse-links

Type: SPV14, SPV22

Rating: 690 V AC, 63 A, 125 A

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 003847-01/01 of: 13.10.2010

A sample of the product was found to be in conformity with:
ČSN EN 60269-1 ed.3:08 +A1:10, ČSN 35 4701-2:08

The validity of the certificate is limited to: 31.10.2013

20.10.2010

Prague

Miroslav Sedláček
Certification and Inspection Manager



Stamp



003847-01