

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1110007

Product: Fuse-links for protection of semiconductors devices

Type: P4...10, P5...10 aR

Rating: 1000 V AC, 80-700 A

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 003189-01/01 of: 28.12.2010

A sample of the product was found to be in conformity with:
ČSN EN 60269-1ed. 3:08+A1:2010, ČSN EN 60269-4 ed. 3:10

The validity of the certificate is limited to: 31.1.2014

4.1.2011

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



* C E R / 1 1 1 0 0 0 7 *

003189-01