

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1110081

Product: Fuses for use by authorized persons

Type: PLN1gG, PLN2gG

Rating: 400 V AC, 6-400 A

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 100108-01/01 of: 14.01.2011

A sample of the product was found to be in conformity with:
ČSN EN 60269-1 ed.3:08+A1:10, ČSN 35 4701-2:08, IEC 60269-1:98, IEC 60269-2-1 ed.3:02

The validity of the certificate is limited to: 31.1.2014

24.1.2011

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



100108-01