

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1080555

Product: Shunt trip

Type: SV-LP-X060, SV-LP-X400 AC/DC

Rating: SV-LP-X060 = 12-60 V AC/DC; SV-LP-X400 = 110-415 V AC, 100-220 V DC

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 801699-01/01 of: 26.05.2008

A sample of the product was found to be in conformity with:
ČSN EN 60947-1:08 ed.4 cl.5, 5.1, 5.2, 7.1.8.4, 7.2.3.1, 7.1.3, 5.2.1, 7.2.4.1a), 7.1.4,
ČSN EN 60947-5-1:05 ed. 2+1:05 cl.7.2.4.3, 7.2.4.1a), 7.1.3,
ČSN EN 60898-1:03+A1:05+1:05+A11:06 cl.9.3, 9.4, 9.14.1, 9.13.2, 9.14.2, 9.15

The validity of the certificate is limited to: 30.6.2011

10.6.2008

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



801699-01