

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRUFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1090077

Product: Circuit breaker

Type: LPE

Rating: 230/400 V; 6-63 A; char. B, C

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 805078-01/01 of: 23.01.2009

A sample of the product was found to be in conformity with:
ČSN EN 60898-1:03+A1:05+1:05+A11:06+A12:08

The validity of the certificate is limited to: 31.1.2012

28.1.2009

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



805078-01