

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÉQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1090130

Product: Residual current circuit breakers

Type: OLE, OLI

Rating: AC 230 V, In 6, 8, 10, 13, 16, 20, 25, 32, 40 A; Ires. 0,01; 0,03; 0,1; 0,3 A; 50/60 Hz; Icn 4,5; 6; 10 kA; char. B, C

Ordering firm: OEZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: Siemens AG A&D CD
Werner-von-Siemens-Strasse 48, D-92220 Amberg, Germany

Trade mark:

The test results are stated in the test-report No.: 805073-01/01 of: 10.02.2009

A sample of the product was found to be in conformity with:
ČSN EN 61009-1:05 ed.2+1:07+A11:08; ČSN EN 61009-2-1:97+A11:99

The validity of the certificate is limited to: 28.2.2012

20.2.2009

Prague

Pavel Kudrna
Certification and Inspection Manager



Stamp



805073-01