

ELEKTROTECHNICKÝ ZKUŠEBNÍ ÚSTAV



ELECTROTECHNICAL TESTING INSTITUTE - CZECH REPUBLIC
ELEKTROTECHNISCHE PRÜFANSTALT - TSCHHECHISCHE REPUBLIK
INSTITUT ELECTROTECHNIQUE D'ESSAIS - RÉPUBLIQUE TCHÈQUE
ЭЛЕКТРОТЕХНИЧЕСКИЙ ИСПЫТАТЕЛЬНЫЙ ИНСТИТУТ - ЧЕШСКАЯ РЕСПУБЛИКА

Pod Lisem 129, 171 02 Praha 8 - Troja

CERTIFICATE

No.: 1110810

Product: Plastic box for switchboard

Type: CX-2, CX-4

Rating: 400 V, to 63 A, IP 30, IK 07

Ordering firm: O EZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Manufacturer: O EZ s. r. o.
Šedivská 339, 561 51 Letohrad, Czech Republic

Trade mark:

The test results are stated in the test-report No.: 101758-01/01 of: 07.09.2011

A sample of the product was found to be in conformity with:
ČSN EN 62208:2004 cl.6.1, 6.2, 9.9.2, 9.6, 9.10, 9.7, 8.6, 9.8

The validity of the certificate is limited to: 30.9.2014

19.9.2011

Prague

Miroslav Sedláček
Head of Certification Body



Stamp



101758-01